



GENERAL NOTES:

1. The Secondary wires point of attachment must be in a path that is clear of obstructions and vegetation.
2. There shall be a minimum of three conduit straps for support on the conduit. The conduit shall be 2 1/2 inch rigid.
3. Attachment height shall be based on the most current version of the NESC. Currently 18' minimum above public streets, alleys, and cultivated fields. 16' minimum above residential driveways, and 12' minimum above finished grade and walkways.
4. Service entrance conductor must extend 36" minimum from the weather head for connecting purposes.
5. Ground wires shall be unspliced in accordance with the most current version of the NEC. Driven ground rods and clamp shall be below grade.



OVER HEAD SERVICE
 PERMANENT METER BASE
 DOUBLE WIDE HOME

DATE: 12-7-23

STANDARD NUMBER

MB-OH D/W